

THE STRAND ELECTRIC & ENGINEERING CO LTD

JOB A.B.G. YARMOUTH
RACK/BANK 3 x 24 x 2kw

SYSTEM LC.
CABINET LCCR 72
DEPT. I.E.

DATE 7. 2. 64
LAYOUT DWG
SHEET 1 OF 3

ORIGINATOR L.W. HEARN.

CIRCUIT	COLOUR	DESCRIPTION	RACK	CHANNEL	PHASE	MAX LOAD
1	R	F.O.H. Circle	2	21	R	3
2	"	" "	2	22	R	3
3	"	" "	2	23	R	3
4	"	" "	2	24	R	3
5	"	" "	1	21	R	3
6	"	" "	1	22	R	3
7	"	" "	1	23	R	3
8	"	" "	1	24	R	3
9	BLU	" side	1	1	R	2
10	"	" "	1	2	R	2
11	"	" "	1	3	R	2
12	"	" "	1	4	R	2
13	"	" "	1	5	R	2
14	"	" "	1	6	B	2
15	RED	No. 1 Spot Bar 1	1	7	Y	1
16	"	" " " 2	1	8	Y	1
17	"	" " " 3	1	9	Y	1
18	"	" " " 4	1	10	Y	1
19	"	" " " 5	3	1	Y	1
20	"	" " " 6	3	2	Y	1
21	"	" " " 7	3	3	Y	1
22	"	" " " 8	3	4	Y	1
23	"	" " " 9	3	5	Y	1
24	"	" " " 10	3	6	Y	1
25	"	" " " 11	3	7	Y	1
26	"	" " " 12	3	8	Y	1
27	"	" " " 13	3	9	Y	1
28	"	" " " 14	3	10	Y	1
29	"	" " " 15	3	11	Y	1
30	"	" " " 16	3	12	Y	1
31	BLU	No. 2 Boom A.L. TOP	2	1	B	1
32	"	" " A.R. "	2	2	B	1
33	"	5 A.L. "	2	3	B	1
34	"	3 A.R. "	2	4	B	1
35	"	4 A.L. "	2	5	B	1
36	"	4 A.R. "	2	6	B	1
37	"	No. 1 Boom A.L.	2	7	B	2
38	"	" 1 " A.R.	2	8	B	2
39	"	" 2 " A.L.	2	9	B	1
40	"	" 2 " A.R.	2	10	B	1

8 x 3k

6 x 2k

16 x 1k

4 x 2

THE STRAND ELECTRIC & ENGINEERING CO LTD

A.B.C. YARMOUTH
 RACK/BANK 3 x 24 x 2kw.
 ORIGINATOR L.W. HEARN.

SYSTEM LC.
 CABINET LCCR 72
 DEPT IE

DATE 7.2.64
 LAYOUT DWG
 SHEET 2 OF 3

CIRCUIT	CLOUR	DESCRIPTION	RACK	CHANNEL	PHASE	MAX LOAD
41	R.	No. 2 Boom A.L.	2	11	B	1
42	"	" 2 " A.R.	2	12	B	1
43	"	" 2 " A.L.	2	13	B	1
44	"	" 2 " A.R.	2	14	B	1
45	"	" 3 " A.L.	2	15	B	1
46	"	" 3 " A.R.	2	16	B	1
47	"	" 3 " A.L.	2	17	B	1
48	"	" 3 " A.R.	2	18	B	1
49	"	" 3 " A.L.	2	19	B	1
50	"	" 3 " A.R.	2	20	B	1
51	"	" 4 " A.L.	1	11	B	1
52	"	" 4 " A.R.	1	12	B	1
53	"	" 4 " A.L.	1	13	B	1
54	"	" 4 " A.R.	1	14	B	1
55	"	" 4 " A.L.	1	15	B	1
56	"	" 4 " A.R.	1	16	B	1
57	BLU	No. 1 BATTEN	3	13	Y	2
58	"	" "	3	14	Y	2
59	"	" "	3	15	Y	2
60	"	" "	3	16	Y	2
61	R	No. 2 " 8 x 2 k	3	17	Y	2
62	"	" "	3	18	Y	2
63	"	" "	3	19	Y	2
64	"	" "	3	20	Y	2
65	B	Cyc. Fld. Bar	3	21	Y	3
66	"	" " " 4 x 3k	3	22	Y	3
67	"	" " "	3	23	Y	3
68	"	" " "	3	24	Y	3
69	R	Cyc. Grd/Row	1	17	B	2
70	"	" " 4 x 2k	1	18	B	2
71	"	" "	1	19	B	2
72	"	" "	1	20	B	2

VOLTAGE 240V

FREQUENCY 50[~]

THE STRAND ELECTRIC & ENGINEERING CO LTD

JOB A.B.C. YARMOUTH
 RACK/BANK 3 X 24 X 2KW.
 ORIGINATOR. L.W. HEARN.

SYSTEM LC.
 CABINET LCCR 72
 DEPT. I.E.

DATE 7.2.64
 LAYOUT DIAG
 SHEET 3 OF 3

CIRCUIT	COLOUR	DESCRIPTION	RACK	CHANNEL	PHASE	MAX LOAD
<u>SWITCHED ONLY CIRCUITS</u>						
1		Dips A.L.	4	1	B	2
2		" A.L.	4	2	B	2
3		" A.R.	4	3	B	2
4		" A.R.	4	4	B	2
5		Flys A.L.	4	5	B	2
6		" A.R.	4	6	B	2
7		Effects Motor A.L.	4	7	B	1
8		" " A.R.	4	8	B	1
Switched only circuits 1-8 to be subject to B/O.						
<u>RACK LOADINGS</u>						
		R	B	Y		
Rack 1		24	14	4		
" 2		12	22	-		
" 3		-	-	40		
" 4			14		Switched only.	
SPOTS						

VOLTAGE 240V

FREQUENCY 50 ~

65-72 CHANNELS

Handwritten mark resembling a stylized 'U' or 'V' with a horizontal line.

15 - 23 26 - 30 CHANNELS

LINE NO.	TYPE	DESCRIPTION	DATE	TIME
1	B			
2	B			
3	U			
4	B			
5	B			
6	B			
7	B			
8	B			

LINE NO.	TYPE	DESCRIPTION	DATE	TIME
9	B			
10	B			
11	B			
12	B			
13	B			
14	B			
15	B			
16	B			
17	B			
18	B			
19	B			
20	B			
21	B			
22	B			
23	B			
24	B			
25	B			
26	B			
27	B			
28	B			
29	B			
30	B			